



- IF MULTIPLE TANKS ARE REQUIRED, THEY MUST BE MANIFOLDED TOGETHER INTO A SINGLE RISER.
- RISER SHALL BE A MINIMUM OF 1.5 x BUILDING HEIGHT AWAY FROM BUILDING. HOWEVER, IT IS OFTEN AN ADVANTAGE FOR PROPERTY OWNERS AND THE FIRE DEPARTMENT TO HAVE RISER INSTALLED A SIGNIFICANT DISTANCE AWAY FROM BUILDING (UP TO 100')
- PREFERRED METHOD FOR RISER LAYOUT IS TO CONTACT MARION COUNTY FIRE - PREVENTION AT 291-8000

\*\* THIS DETAIL IS A GENERAL REPRESENTATION AND IS NOT TO SCALE.

**DRY HYDRANT DETAIL**  
**EXAMPLE OF A SINGLE TANK SYSTEM**